


DIG PERMIT REPAIR FOR WATER & SEWER LATERALS



STANSBURY PARK IMPROVEMENT DISTRICT
#30 PLAZA, STANSBURY PARK, UTAH 84074
435-882-7922

EMAIL: SUPPORT@STANSBURYWATER.GOV
WEBSITE: STANSBURYWATER.GOV

Contractor's Name:
License #:

Contact Person:

Telephone:

Contractor's Address:

City:

State:

Zip:

Property Owner:

Work Location/Address:

Work Start Date:

Work Completion (Expiration) Date:

Permit #:

Description of Work:

Sketch of Location and Plan (attach figures as necessary):

CONSTRUCTION WITHOUT INSPECTION IS SUBJECT TO REJECTION

I hereby acknowledge that the information I have provided is correct and agree that all shall be in accordance with applicable provisions of Stansbury Park Improvement District and Utah Code. On behalf of the owner, or as the owner, I herewith consent to all necessary inspections.

Applicant Signature: _____ **Date:** _____

FOR OFFICE USE ONLY

Approval for Issuance by: _____ **Date:** _____

Additional Conditions: _____

Final Inspection by: _____ **Date:** _____

Application & Inspection Fee: \$70.00 Additional costs after 1 hour may apply.

Date Paid: _____ **Check Number:** _____ **Stamp:** _____

The following is a summary of the requirements provided in Resolution 2010-3 Utah Code 17a-2-312 of Stansbury Park Improvement District. The requirements provided below must be met for all excavation projects within Stansbury Park.

- **Call Before You Dig:** All utilities must be located prior to performing any excavation work (includes directional drilling) call Blue Stakes 811. Contact Tooele County Building for a permit.
- **Permits Must Be Procured Before Starting to Work:** If any work requiring a permit is commenced without a permit first having been obtained therefore, the District may immediately issue a stop work order until the proper permits and approvals are obtained, and such an offender shall, in addition to any other penalties, be charged double the regular permit/inspection fee
- **Damaged Utilities:** Contractor shall be responsible for repairing any damaged utilities marked through the Blue Stakes locate request as well as any damage to private water and sewer service laterals.
- **Damage to District Facilities:** Should any act or omission of any person result in damage to the District's main water and/or sewer lines and/or any other facilities or apparatus of the District, such as damage caused by grease escaping into the District's sewer main, or to any facility or apparatus of the District, the responsible person shall reimburse to the District as appropriate, all costs and expenses associated with repairing and remediating the damage, including repairs to lines and facilities and any and all fines and penalties assessed against the District. The District Manager shall have authority to adjust a customer's monthly bill to collect the repair and remediation costs, over a period of up to one year.
- **As-Built Drawings:** As-built drawings or sketches showing the general location of utilities installed within the right-of-way shall be provided to the Stansbury Park Improvement District upon completion of the work.
- **Revocation of Permit:** The District Manager may, at any time, revoke a permit because of defective work which has not been corrected after written notice and within the time specified therein by the District Manager
- **Permit Not Transferrable:** No sewer contractor or plumber shall use or allow his license to be used in any way for the purpose of procuring a permit for any person other than himself, or his duly authorized representative. The duly licensed and bonded sewer contractor or plumber shall be responsible for any and all work done pursuant to the issuance of any permit specified hereunder, regardless of whether the work is actually done by said contractor or his duly authorized representative.
- **Fee for Inspections:** Application for permits for sewer repair or replacement of any sewer line must be made in writing by the property owner and work conducted by a licensed and bonded sewer contractor or plumber. Repair or replacement of any sewer line shall be tested and inspected in accordance with standards set by the District and Tooele County. A fee shall be determined and collected by the District for each such inspection.
- **Inspection Required:** The inspection of sewer lines between the District sewer main and a building foundation shall be under the direction of the District or by its duly authorized inspectors and Tooele County. The District shall be notified on a regular working day at least 24 hours in advance of the time the permittee requests inspection. The entire length of the building sewer, including the junction at the District sewer, shall be fully exposed, (if applicable). Any portion of the work not performed in accordance with these requirements and the instruction of the District and Tooele County inspectors, shall be corrected promptly. There shall be no backfilling until the inspection is made and the work accepted. No certificate of inspection shall be issued until the work is satisfactorily performed and accepted. Lateral shall not be placed on loose or un-compacted ground and shall be supported by $\frac{3}{4}$ " rock, or District approved equivalent.
- **District Standards for Construction, Repair and Maintenance:** All construction repairs and maintenance undertaken in connection with the water and sewer systems of the District shall be accomplished under the supervision of and in accordance with standards established by the District.
- **Standard Connection: Water laterals-** Require IPS Poly pipe which is $\frac{3}{4}$ inch in diameter and 30"- 48" max depth. Place 14-gauge tracer wire directly over pipe. Grease and wrap all fittings. 1' sand or bedding fines are required above pipe unless permission is otherwise granted by the District to install a larger pipe size. **DO NOT USE GALVANIZED FITTINGS. Sewer laterals-** Require to be bedded with $\frac{3}{4}$ " gravel, 6" under and 1' above pipe. Place 14-gauge tracer wire directly over pipe. **USE ONLY STAINLESS RIGID FERNCO WRAP COUPLINGS.** Install test tee and clean out. Lateral slope shall be 2% + per standards established by the District.